

Technical data HydroFixx 80/80 – Pipe distance (OC) 125mm (4 15/16")

Combined flow and return manifold with adjacent chambers separated by a sinusoidal partition wall, with horizontally welded-on subjacent Hydronic Junction. Manifold consists of S235 square profiles. Feeding from/to the heating boiler can be carried out either to the upper Sinus Compact Manifold or to the lower Hydronic Junction.

Pressure loss in flow and return

Pressure loss diagram illustrating the respective pressure loss depending on the water flow rate at the given number of heating circuits.



Number of heating circuits	Length		Capacity at ∆T 20 K		Heating water flow rate		Water con- tent		Connection to heating circuits/ Connection to boiler circuit	Pipe distance		Wall thickness	
[HC]	[mm]	[in inch]	[kW]	[MBH]	[m³/h]	[gpm]	[1]	[gal]	[in inch]	[mm]	[in inch]	[mm]	[in inch]
2	460	18.1	70	238.8	3.0	13.2	2.5	0.7	Flare and 1 ½" union nut/1 ½" NPT	125	4 15/16''	2.5	0.1
3	710	28.0	70	238.8	3.0	13.2	3.9	0.7	Flare and 1 ½" union nut/1 ½" NPT	125	4 15/16''	2.5	0.1